

WW INOP
Dataset 09.09.2017 1130hrs

county <div style="border: 1px solid #ccc; padding: 2px; margin-bottom: 2px;">ARANSAS</div> <div style="border: 1px solid #ccc; padding: 2px; margin-bottom: 2px;">Brazoria</div> <div style="border: 1px solid #ccc; padding: 2px; margin-bottom: 2px;">Fort Bend</div> <div style="border: 1px solid #ccc; padding: 2px; margin-bottom: 2px;">Galveston</div> <div style="border: 1px solid #ccc; padding: 2px; margin-bottom: 2px;">Hardin</div> <div style="border: 1px solid #ccc; padding: 2px; margin-bottom: 2px;">Harris</div>	vvCurrentStatus <div style="border: 1px solid #ccc; padding: 2px; margin-bottom: 2px;">DES</div> <div style="border: 1px solid #ccc; padding: 2px; margin-bottom: 2px;">INOP</div> <div style="border: 1px solid #ccc; padding: 2px; margin-bottom: 2px;">NonOp</div>	facilityName <div style="border: 1px solid #ccc; padding: 2px; margin-bottom: 2px;">ARANSAS NATIONAL ...</div> <div style="border: 1px solid #ccc; padding: 2px; margin-bottom: 2px;">ARCHDIOCESE OF GA...</div> <div style="border: 1px solid #ccc; padding: 2px; margin-bottom: 2px;">BEACH ROAD MUD - ...</div> <div style="border: 1px solid #ccc; padding: 2px; margin-bottom: 2px;">BLOOMINGTON ISD -...</div> <div style="border: 1px solid #ccc; padding: 2px; margin-bottom: 2px;">BLUE RIDGE WEST M...</div> <div style="border: 1px solid #ccc; padding: 2px; margin-bottom: 2px;">BOLIVAR UTILITY SER...</div> <div style="border: 1px solid #ccc; padding: 2px; margin-bottom: 2px;">BRAZORIA COUNTY</div>
---	---	---

Total				35
vvCurrentStatus	ID	facilityName	comments_Second	county
NonOp	4917000	ARANSAS NATIONAL WILDLIFE REFUGE WATER PLANT	Facility contact was made but the system is still being assessed. The contact stated that he would call back Wednesday with an update. Please note the waste stream	ARANSAS
NonOp	14218001	ARCHDIOCESE OF GALVESTON HOUSTON - CIRCLE LAKE RETREAT CENTER WWTP	4. No power 10. no power, not currently collecting 13. On generator within one day hopefully Phone number 281-356-6764 not functional possibly due to storm.	Montgomery
INOP	13563001	BEACH ROAD MUD - BEACH ROAD MUD WWTP	Tornado hit, the clarifier was hit by debris, draining system and trucking wastewater to Bay City, WWTP. The collection system is	Matagorda
INOP	14578001	BLOOMINGTON ISD - BLOOMINGTON JUNIOR HIGH AND HIGH SCHOOL WWTP	School has been cancelled until 9/18/17. Power expected to be restored by 9/11/17 at which time an assessment of the WWTP can be accomplished.	Victoria
INOP	11553001	BLUE RIDGE WEST MUD - BLUE RIDGE WEST MUD WWTP	Operator stated that the area is flooded but it seems that the plant is okay. Plant is still online. Cannot assess plant so overall status is unknown.	Fort Bend
DES	12936001	BOLIVAR UTILITY SERVICES LLC - CRYSTAL PALACE WWTP	Crystal Palace completely destroyed, no access	Galveston

WW INOP
Dataset 09.09.2017 1130hrs

vvlCurrentStatus	ID	facilityName	comments_Second	county
NonOp	14724003	BRAZORIA COUNTY MUD 55 - BRAZORIA COUNTY MUD 55 WWTP	Facility seems to be okay but the area is flooded. Facility is still online. Facility cannot be assessed so the overall status is unknown.	Brazoria
INOP	11713001	CEDAR BAYOU PARK UTILITY DISTRICT - CEDAR BAYOU PARK WWTP	Finally able to access plant on 9/4/17 (by foot), bridge and road damage preventing vehicle access. Electrician expected on site 9/5/17 and insurance claims are underway. Entire service area evacuated, no inflow being received. Contact mentioned Ci	Harris
INOP	1006000	CHEVRON PHILLIPS CEDAR BAYOU CHEMICAL PLANT		HARRIS
INOP	13172002	CINCO MUD 1 - CINCO RANCH SOUTH WWTP	Waiting on a status update on WWTP. Alot of information was unknown.	Fort Bend
INOP	14581001	CITY OF BRAZORIA - CITY OF BRAZORIA WWTP	The plant and lift stations are under water. Have ask for a strike team to help get the back in working order for the Texas City SOC. All electial system are under water they are hoping the they dry out the system and they work. They will need to rep	Brazoria
NonOp	10495149	CITY OF HOUSTON - FOREST COVE WWTP	Massive structural and electrical panels missing from Aqua Vista lift station Forest Cove Dr #1, Forest Cove Dr #2, Marina, Trail Tree Lane lift station are inoperable	Harris
NonOp	10495146	CITY OF HOUSTON - KINGWOOD CENTRAL WWTP	The UV disinfection system was damaged. Temporary chlorination is being used. Ag Farm, Deer Ridge, Deer Springs, Stately Oaks, Woodland Ridge lift stations are partially operational. Aspen Bend, Bens Branch, Forest Garden, Riverchase Trail, Riverlawn,	Harris
NonOp	10495109	CITY OF HOUSTON - TURKEY CREEK WWTP	Water Quality Division received an email for City of Houston (COH) on 9/8/17. COH indicates major damage is assumed. The WWTP is inaccessible due to high water. The Briar Forest list station is on generator. Fleetwood, Harvet Moon, Kirkwood #3, Mud 10	Harris

WW INOP
Dataset 09.09.2017 1130hrs

vvCurrentStatus	ID	facilityName	comments_Second	county
INOP	10495030	CITY OF HOUSTON - WEST DISTRICT WWTP	Water Quality Division recieved an email from the City of Houston (COH) with the completed wastewater evaluation form on 9/8/17. COH indicates the overall status of the treatment plant and collection sytem is not fully known at this time. Based on the s	Harris
INOP	10108001	CITY OF LIBERTY - CITY OF LIBERTY MAIN WWTP	The plant is currently under water. The city major and some of the minor lift stations are operatonal. It will be days before they will be able asset the plant. They are currently working on getting the minor lift stations up and running to get the sew	Liberty
INOP	10312001	CITY OF WEST COLUMBIA - CITY OF WEST COLUMBIA WWTP	The plant and lift stations are under water. They hop to due a full assessment on the system by Friday.	Brazoria
NonOp	11844001	FOREST GLEN INC - FOREST GLEN WWTF	#4. Facility currently pumping and hauling to Richey Rd MUD. #5. Access road washed out. 3 Aeration tanks and 1 digester and undercut tank shifted. Plumbing was pulled away from all tanks. 1 aeration tanks was cracked at the bottom and is not usable (mu	Walker
INOP	14564001	FORT BEND COUNTY MUD 162 - FORT BEND COUNTY MUD 162 WWTP	The facility is flooded however the facility is still online. Facility cannot be assessed so the overall status is unknown.	Fort Bend
INOP	13628001	FORT BEND COUNTY MUNICIPAL UTILITY DISTRICT 112 - NEW TERRITORY NORTH REGIONAL WWTP	Plant appears to be online but is flooded. Unable to assess therefore overall status is unknown.	Fort Bend
INOP	10678001	HARDIN COUNTY WCID 1 - HARDIN COUNTY WCID 1		Hardin
NonOp	10932001	HARRIS COUNTY - BEAR CREEK PIONEERS PARK WWTP	Plant is underwater. Unable to adeqautely assess. Did a drone fly over of the plant and it is flooded. The POC Stated: Control panels are currently underwater. Blowers motor needs to be replaced. Chlorine pumps need to be replaced. Chlorine drum is loo	Harris

WW INOP
Dataset 09.09.2017 1130hrs

vvICurrentStatus	ID	facilityName	comments_Second	county
NonOp	670000	HONEYWELL INTERNATIONAL ORANGE PLANT	Gravity flow collection system waiting for flood water to receed. Collection system restoration time unknown.	ORANGE
INOP	11290001	JACKRABBIT ROAD PUD - JACKRABBIT ROAD PUD WWTP	5 ft of water in facility David Walker 8322501142 has more informtion on the plant 09/05/2017 - Called David Walker -Facility is still underwater, getting portable generator to operate lift station, and start chlorinating wastewater - Collection system	Harris
INOP	14205001	LAMAR CISD - FOSTER BRISCO SCHOOL COMPLEX	WWTP is flooded and cannot be assessed, however facility is online. Overall staus is unknown.	Fort Bend
NonOp	1727000	LNVA NORTH REGIONAL TREATMENT PLANT	Pumping flood water out of plant. Will assess damage.	JEFFERSON
INOP	13839001	MAURICEVILLE MUD - MAURICEVILLE WWTP	3 lift stations are up, and One lift station is down. Many grinder pumps not working due to flooding.	Orange
INOP	11329001	NEWPORT MUD - NEWPORT MUD WWTP	39 Million gallons of water is covering the system. No Power. They are flooded. They are next to an 8foot levee San Jacinto River. They are trying to get their hands on pumps. They evacuated the plant. They are still in need of pumps. they have pumps but	Harris
NonOp	10875001	ORANGE COUNTY WCID 1 - OAK LANE WWTP	The facility is experieicing by pass. They have no power and he facity is not operational. There is not current disinfection	Orange
NonOp	12113001	ORBIT SYSTEMS INC - BEECHWOOD WWTP	Unable to see the facility. The POC is not the facility owner anymore. The condition of the damage is unknown. August 28, 5 to 7 days of not having access. A mandatory evacuation. A drainage ditch must be crossed to access the facility. There is only 1 co	Brazoria
NonOp	3530000	PORT ARTHUR PRODUCTS STATION	Pumps to system completely to flooded or burned up. Will need replacing. Currently using Vac truck to pump and haul tank farm water or oil sheen. System only received intermittant in flow currently not discharging.	JEFFERSON

WW INOP
Dataset 09.09.2017 1130hrs

vvCurrentStatus	ID	facilityName	comments_Second	county
INOP	13804001	TEXAS DEPARTMENT OF CRIMINAL JUSTICE - TERRELL WWTP	Prison has been evacuated and WWTP and other systems shut down. Personnel currently on-site at prison, WWTP is still flooded and not accessible. Resources are being dedicated to addressing potable water issues.	Brazoria
INOP	11141001	TRESCHWIG JOINT POWERS BOARD - TRESCHWIG CENTRAL WWTP	Plant is offline - flooded (unknown status)	Harris
INOP	12088001	US ARMY CORPS OF ENGINEERS - ROCKY CREEK PARK WWTP	Park is closed and no inflows to WWTP are occurring. WWTP has been turned off and is idle. Lift station is under water and extent of damage throughout system is unknown. Contact indicated would likely be the end of October before plant can be accessed	Washington
NonOp	3891000	WHARTON COUNTY GENERATION FACILITY	flooding on-site. Site is no longer flooded. Forced turbine outage prior to Harvey. Cleanup phase currently ongoing. Damaged electrical components (2-4 weeks until power restored). Not using waste water permit, filed for water reuse, sprinkler system/no d	WHARTON
35				